

STANDARD INFORMATION

Standard: UL 1978

Standard ID: Grease Ducts [UL 1978:2010 Ed.4+R:02Apr2024]

Previous Standard ID: Grease Ducts [UL 1978:2010 Ed.4+R:11Oct2021]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **April 2, 2026**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Addition of Testing for Fiber Woven Gaskets. Specific details of new/revise requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
21	Info	Tensile Strength, Elongation, And Change In Volume Tests Of Gaskets And Seals
21.1	Info	General
		<i>New clause added;</i>
21.1.0		Compressed fiber and fiber woven gasket and seal materials shall comply with the requirements in Section 21A. Elastomer gasket and seal materials used in the construction shall comply with 21.1.1 and 21.1.2.
		<i>New section added;</i>
		Fiber Woven Grease Gasket Density, Moisture Analysis, and Compression
21A		Section 21A requirements are specifically applicable to fiber woven material used as gaskets in grease duct assemblies. The methods described and defined in this section are in lieu of Section 21, Tensile Strength, Elongation, and Change in Volume Tests of Gaskets and Seals.
		See standard for details.